



Town of Mount Pleasant Fire Department
Mike Mixon, Fire Chief
 100 Ann Edwards Lane
 Mount Pleasant, South Carolina 29464
 (843) 884-0623 voice (843) 849-5358 facsimile



Mobile Food Vendor Fire Safety Inspection

Date:	Inspector:
Business Name:	Vendor Phone:
Address:	
License #:	Vendor Name:

GENERAL REQUIREMENTS	N/A	YES	NO
1. Mobile food vendor shall be located at least 10 feet from buildings.			
2. Mobile food vendor shall be located at least 10 feet from fire hydrants and FDC.			
3. Mobile food vendor shall be located at least 10 feet from other mobile food vendors.			
4. Mobile food vendors shall not obstruct any access to or exit from a structure.			
5. Proper no smoking sign shall be posted in public view.			
6. Current business license, operational permit, and DHEC permit shall be posted in public view.			
ELECTICAL/GENERATOR	N/A	YES	NO
1. Generator shall be located at least 10 feet from any structure/vehicle. (Downwind if possible)			
2. Extension cords are only used on a temporary basis, never in place of permanent wiring.			
3. Extension cords must be in good condition, free from obvious damage to cord or plug.			
4. Breaker box does not have any open slots or circuits; circuits are clearly labeled with cover closed.			
5. Electrical panel is clear and accessible.			
6. All electrical junction box covers, outlet covers, and switch plates are secured in place.			
PROPANE / LPG	N/A	YES	NO
1. Ensure that all propane tanks are properly mounted or secured in upright position to prevent tipping.			
2. The propane shutoff valves must always be accessible to ensure they can be utilized if needed.			
3. Propane hoses and connections must be in good repair and free from leaks.			
4. Flexible connector is installed between the regulator outlet and the fixed piping system.			
5. Maximum aggregate capacity of LP-gas containers on the vehicle shall not exceed 200 pounds.			
6. A listed LP-gas alarm is installed near LP-gas components, per manufacturer's instructions.			
7. LP-gas containers have been inspected by an approved inspection agency			
8. Date of manufacture, if new or a requalification stamp is required on all stamps (12 year).			
PROPANE / LPG APPLIANCES	N/A	YES	NO
1. All appliances installed on mobile food vendor shall be listed for use with propane.			
2. Appliances shall be readily accessible.			
3. Appliances shall not block egress.			
4. Manual shutoff valve shall be easily accessible.			
FIRE EXTINGUISHERS	N/A	YES	NO
1. All mobile food vendors shall have a 2A:10BC fire extinguisher.			
2. When cooking operations produce grease laden vapors-One 1.5 Gallon type K extinguisher is required.			
3. One K extinguisher for every 4 deep fryers with an oil capacity of 80 pounds.			
4. All extinguishers shall be visible, accessible, mounted, and inspected.			
KITCHEN HOOD	N/A	YES	NO
1. Hood exhaust system shall be inspected tagged by a qualified vendor, bi-annually.			
2. Hood exhaust system shall be clean and operational.			
3. Hood exhaust shall be clear of trees or any other obstruction.			
4. Exhaust fan must be running while cooking operations are taking place.			
EXIT PATH	N/A	YES	NO
1. The exit path shall be clear of any obstructions to include during food preparation and serving.			
2. The exit path must be recognizable and clear of any tripping hazards.			
3. Exit doors must open with ease.			
ON-SITE REQUIREMENTS	N/A	YES	NO
1. All cooking surfaces are clean and free of combustible materials.			
2. Storage, stock, etc. is orderly and no excessive, ensuring items do not become a safety concern.			
3. Cooking oil storage shall have a maximum aggregate volume of not more than 120 gallons.			